



PLANTA

CODO

SECCIÓN Y-Y'





CODO 90°	Ø mm	100	150	250	300	500
	A	0.40	0.60	1.00	1.10	1.80
	B	0.30	0.40	0.60	0.80	1.30
	C	0.70	0.80	0.90	0.90	1.10
LECHO DE ARENA		0.10	0.10	0.15	0.15	0.20

CODO 45°	Ø mm	100	150	250	300	500
	A	0.30	0.40	0.70	0.80	1.20
	B	0.20	0.30	0.50	0.70	0.80
	C	0.40	0.50	0.60	0.70	0.80
LECHO DE ARENA		0.10	0.10	0.15	0.15	0.20

PLANTA

T

SECCIÓN Z-Z'



T Ø DERIVACIÓN	Ø mm	100	150	250	300	500
	A	0.30	0.50	0.70	0.80	1.30
	B	0.30	0.40	0.60	0.80	1.30
	C	1.10	1.25	1.40	1.40	1.70
LECHO DE ARENA		0.10	0.10	0.15	0.15	0.20

NOTAS:

- HORMIGÓN HA-25
- PRESIÓN DE SERVICIO 5 kg/cm²
- TENSIÓN TRANSMITIDA AL TERRENO 1 kg/cm²
- TODAS LAS UNIONES QUEDARÁN LIBRES
- ENTRE LA SUPERFICIE DE LA TUBERÍA Y EL HORMIGÓN SE COLOCARÁ UNA LÁMINA DE MATERIAL PLÁSTICO

COTAS EN m

MODELO:

**MACIZO DE CONTRARRESTO:
CODO Y T**

ESCALA ORIGINAL A4:

S/E

ESCALA GRAFICA:



M-14-1

ABRIL 2025